



**SOUTHWEST GAS CORPORATION**  
**NOTICE OF HAZARDOUS CONDITIONS ON CUSTOMER'S PREMISES**

No. 1424228

This notice is given for your protection only.

Address 2256 LOSEERY Apt. space No. C Meter Left  On  Off  
 City ALV

A Southwest Gas Representative inspected the gas appliances at the address shown above. The appliances and associated hazardous conditions are listed below. Affected appliances have been left off for your safety.

Appliance:	Heating	Range	Oven	Dryer	BBQ	Gas Log	Gas Piping	Pool Heater	Fire Pit
Conditions Identified:			12						

**Hazardous Conditions**

1	Vent system improperly installed	7	No combustion air
2	Vent restricted	8	Insufficient combustion air causing operational problems
3	Combustibles too close to vent with signs of heat damage	9	Improper burner combustion
4	Possible cracked heat exchanger	10	No Temperature Pressure Relief (TPR) valve
5	Flue restriction	11	A _____ cubic feet per hour leak in piping system
6	_____ not sealed airtight from combustion air	12	See Comments

Comments EXHAUST PRODUCT SPILLS ON DOWN DRAFT DIVERTER WHEN DRAFT HOOD SPILLS ON NEGATIVE PRESSURE ENVIRONMENT - (MAKE UP AIR VOLUME IS LESS THAN VOLUME REMOVED BY EXHAUST)

A permit and inspection from the appropriate building and safety department are required before gas service will be reinstated.

When condition is corrected, contact Southwest Gas at 877-860-6020 for gas service to be reinstated. Only Southwest Gas and Southwest Gas contractors are authorized to reinstate service. FOUND DDD DATED CLOSED (AGAINST CODE)

I have read and acknowledge receipt of the information on both sides of this notice.

Print Name M. ROACH Sign Name \_\_\_\_\_ Date Signed 7-29-19  
 Owner  Tenant  Occupant  Agent Technician Initials JW Truck No. 2587

- See reverse side for important safety information -  
 Distribution: White - Office Canary & Pink - Customer